


	MINIMUM*	TYPE
R1	20'	COMMERCIAL
R2	19.5'	COMMERCIAL
R1	4'	RESIDENTIAL
R2	3.5'	RESIDENTIAL
R3	20'	COMMERCIAL
R3	3'-4 1/2"	RESIDENTIAL
W1	24'	COMMERCIAL
W	12'	RESIDENTIAL

NOTES: CONCRETE APRON AND DRIVEWAY TO BE 5" MIN. THICKNESS.  
 SIDEWALK PANELS THAT ABUT THE DRIVEWAY TO BE 5" MIN. THICKNESS.  
 OTHER SIDEWALK PANELS TO BE 4" MIN. THICKNESS. ALL CONCRETE TO  
 BE 3000 LB. MIX WITH NATURAL COLOR AND BROOM FINISH.

\* IF SITE CONDITIONS PROHIBIT THE USE OF THESE STANDARDS,  
 AN ALTERNATIVE MAY BE SUBMITTED FOR APPROVAL TO THE  
 ENGINEERING DEPT.

\*\* EXPANSION JOINT MATERIAL TO MEET  
 ALDOT SPECIFICATIONS 832.01 & 832.02



**CITY OF MOBILE, ALABAMA  
 ENGINEERING DEPARTMENT**

**CONCRETE DRIVEWAY DETAIL  
 FOR ASPHALT ROADWAY  
 W/CURB & GUTTER STREET**