

APPLICATION NUMBER

5268/5294

A REQUEST FOR

**PARKING AND ACCESS/MANEUVERING SURFACE
VARIANCES TO ALLOW AGGREGATE PARKING AND
ACCESS/MANEUVERING AREAS IN A B-3, COMMUNITY
BUSINESS DISTRICT; PARKING AND
ACCESS/MANEUVERING AREAS MUST BE ASPHALT,
CONCRETE OR AN APPROVED ALTERNATIVE PAVING
SURFACES IN B-3, COMMUNITY BUSINESS DISTRICTS**

LOCATED AT

4213 HALLS MILL ROAD

(East side of Halls Mill Road, 410' ± North of Alden Drive)

APPLICANT/OWNER

ROBERT S. MOORE

BOARD OF ZONING ADJUSTMENT

FEBRUARY 2005

The applicant is requesting Parking and Access/Maneuvering Surface Variances to allow aggregate parking and access/maneuvering areas in an B-3, Community Business District; parking and access/maneuvering areas must be asphalt, concrete or an approved alternative paving surfaces in B-3, Community Business Districts.

The applicant proposes to construct a 40' x 35' storage/garage building with an aggregate parking and access/maneuvering area. The applicant states that a shell parking and access drive absorbs water and is less expensive than asphalt or concrete.

The applicant submitted an Administrative Planned Unit Development application in August 2004 to allow a 40' x 35' (1,400 square feet) building to be used for storage and agarage. The application was approved and required the provision of a 10-foot wide paved drive for vehicular access if the building is used as a garage; the approval of this variance would remove this condition.

A variance application was before the Board at the October 2004, meeting; the applicant asked that the application be heldover until the November 2004, meeting. At the November 2004 meeting, the applicant was not present; therefore, the application was denied.

The applicant was told that the same application could not be reheard by the Board for six months, and that the only options available were to wait six months or to change the application. The applicant resubmitted the same application with no changes to the site plan.

There are several reasons aggregate is not an approved surface, the probability of aggregate to shift onto the right-of-way and adjacent properties, access is not readily delineated, and without the appropriate compaction of the subsurface materials benefits toward impeding run-off will are not achieved.

The Ordinance states that no variance shall be granted where economics are the basis for the application. Additionally, no variance shall be granted unless the Board is presented with sufficient evidence to find that the variance will not be contrary to the public interest, and that special conditions exist such that a literal enforcement of the Ordinance will result in an unnecessary hardship. The Ordinance also states that a variance should not be approved unless the spirit and intent of the Ordinance is observed and substantial justice done to the applicant and the surrounding neighborhood.

Variances are not intended to be granted frequently. The applicant must clearly show the Board that the request is due to very unusual characteristics of the property and that it satisfies the variance standards. What constitutes unnecessary hardship and substantial

ANALYSIS—APPLICATION 5268/5294

Page 2

justice is a matter to be determined from the facts and circumstances of each application, and as stated above, not based upon economics.


The applicant failed to illustrate that a literal enforcement of the zoning Ordinance would result in an unnecessary hardship. It is simply the applicant's desire to construct an access/maneuvering area with substandard material.

RECOMMENDATION 5268/5294

Date: February 14, 2005

Based upon the preceding, this application is recommended for denial.


LOCATOR MAP



APPLICATION NUMBER 5268/5294 DATE February 14, 2005
APPLICANT Robert S. Moore
REQUEST Parking and Access/Maneuvering Surface Variances



BOARD OF ADJUSTMENT VICINITY MAP - EXISTING ZONING



The site is surrounded by miscellaneous industrial and retail companies, with a single family residential dwelling located at the West.

APPLICATION NUMBER 5268/5294 DATE February 14, 2005


APPLICANT Robert S. Moore

REQUEST Parking and Access/Maneuvering Surface Variances

LEGEND



SITE PLAN



The site is located on the East side of Halls Mill Road, 410' North of Alden Drive. The plan illustrates the existing structures, parking, and drives, along with the proposed structure and shell driveway.

APPLICATION NUMBER 5268/5294 DATE February 14, 2005

APPLICANT Robert S. Moore

REQUEST Parking and Access/Maneuvering Surface Variances

