



THE CITY OF MOBILE, ALABAMA
MOBILE CITY PLANNING COMMISSION

LETTER OF DECISION

September 10, 2014

KEA Marketing, LLC
215 S. Scott Street
Mobile, AL 36602

Re: SUB2014-00094

Myrtle Street Subdivision

2414 Myrtle Street and 264 Chidester Avenue

(North side of Myrtle Street, extending to the East side of Chidester Avenue, 60'±
South of Drake Street).

2 Lots / 1.2± Acre

Dear Applicant(s)/ Property Owner(s):

At its meeting on September 4, 2014, the Planning Commission considered the above referenced subdivision application.

After discussion, the Planning Commission tentatively approved the above referenced subdivision subject to the following conditions:

- 1) **Revision of the Final Plat to illustrate the correct point of beginning and spelling for "Parcel A" and revision of the legal description to include all bearings depicted;**
- 2) **Retention of the lot size information and 25' minimum building setback line on the Final Plat;**
- 3) **Placement of a note on the Final Plat stating that both lots are limited to the existing curb-cuts, with any changes to the size, design, and location to be approved by Traffic Engineering and conform to AASHTO standards;**
- 4) **Placement of a note on the Final Plat stating: *(No future subdivision of Lot 2 to create more lots until additional frontage on a public or private street is provided);***
- 5) **Placement of a note on the Final Plat stating: *(Development of the site must comply with local, state and federal regulations regarding flood zones.);***
- 6) **Placement of a note on the Final Plat stating: *(Development of this site must be undertaken in compliance with all local, state and Federal regulations regarding endangered, threatened or otherwise protected species.);***

- 7) Placement of a note on the Final Plat and compliance with Traffic Engineering Comments: *(Driveway number, size, location and design to be approved by Traffic Engineering and conform to AASHTO standards.);*
- 8) Compliance with Engineering Comments: *(The following comments should be addressed prior to submitting the FINAL PLAT for acceptance and signature by the City Engineer: A. Provide all of the required information on the SUBDIVISION PLAT (i.e. signature blocks, signatures, certification statements, written legal description, required notes, legend, scale, bearings and distances) that is required by the current Alabama State Board of Licensure for Professional Engineers and Land Surveyors. B. Add a note to the SUBDIVISION PLAT stating that a Land Disturbance permit will be required for any land disturbing activity in accordance with the of the Storm Water Management and Flood Control Ordinance (Mobile City Code, Chapter 17 , Ordinance #65-007 & #65-045), latest edition. Storm water detention may be required for any future addition(s) and/or land disturbing activity. C. Add a note to the SUBDIVISION PLAT stating that as shown on the 1984 aerial photo (FLIGHT 27 - #71) each lot will receive the following historical credit of impervious area towards stormwater detention requirement per the Storm Water Management and Flood Control Ordinance (Mobile City Code, Chapter 17, Ordinance #65-007 & #65-045), latest edition, as follows: LOT 1 – 2,900 sf; LOT 2 – 2,100 sf. D. Add a note to the SUBDIVISION PLAT stating that each residential lot will be allowed to add the following impervious area to the lot before storm water detention is required to be provided: LOT 1 – 1,100 sf, LOT 2 – 900 sf. E. Add a note to the Plat stating that the approval of all applicable federal, state, and local agencies (including all storm water runoff, wetland and floodplain requirements) will be required prior to the issuance of a Land Disturbance permit. F. Correct the drawing to show the location of the Point of Beginning for Parcel “A”. G. Show and label the MFFE (Minimum Finished Floor Elevation) on each lot that contains an AE, V, or X (shaded) flood zone designation. H. Provide and label the monument set or found at each subdivision corner. I. Show and label the length of property (Lot 2) (frontage) along the existing ROW of Myrtle Street. J. Provide the Surveyor’s, Owner’s (notarized), Planning Commission, and Traffic Engineering signatures. K. Add a note that sidewalk is required to be constructed along the frontage of each lot, or parcel, at time of development, unless a sidewalk waiver is approved. L. Provide a copy of the Final Plat along with the original when submitting for City Engineer signature.);*
- 9) Compliance with Urban Forestry Comments: *(Property to be developed in compliance with state and local laws that pertain to tree preservation and protection on both city and private properties (State Act 61-929 and City Code Chapters 57 and 64).); and*
- 10) Compliance with Fire Department Comments: *(All projects within the City of Mobile Fire Jurisdiction must comply with the requirements of the 2009 International Fire Code, as adopted by the City of Mobile.).*

Myrtle Street Subdivision
September 4, 2014

After you have obtained all the necessary approval signatures and the plat has been recorded in the Mobile County Probate Office, seven copies of the recorded plat (including map book and page number) must be submitted to the Land Use Administration office. This procedure must be completed within one (1) year, or the Tentative Approval will expire.


It is also requested that a digital copy of the final plat be submitted to the Land Use Administration office once the plat has been submitted to Probate for recording. This may be submitted on disk or via e-mail at marine.karapetyan@cityofmobile.org.

If you have any questions regarding this action, please call this office at 251-208-5895.

Sincerely,

MOBILE CITY PLANNING COMMISSION

Ms. Jennifer Denson, Secretary

By: 
Richard Olsen
Deputy Director of Planning

cc: Rowe Surveying & Engineering Co., Inc.