



THE CITY OF MOBILE, ALABAMA  
MOBILE CITY PLANNING COMMISSION

LETTER OF DECISION

December 22, 2014

Scott & Deborah Krug  
605 Willowbrook Run East  
Mobile, AL 36608

**Re: 4755 McFarland Road**  
(East side of McFarland Road, 805'± North of Three Notch Road).  
County  
**SUB2014-00143**  
**Pine Acres Subdivision, Resubdivision of Lot 1**  
2 Lots / 4.0± Acres

At its meeting on December 18, 2014, the Planning Commission considered the above referenced subdivision application.

After discussion, the Planning Commission tentatively approved the above referenced subdivision subject to the following conditions:

- 1) **dedication to provide 60' from the centerline of McFarland Road;**
- 2) **provision of the lot sizes, in square feet and acres, adjusted after dedication;**
- 3) **illustration of the 25' minimum building setback line, adjusted after dedication;**
- 4) **placement of a note on the Final Plat stating that any lots which are developed commercially and adjoin residentially developed property must provide a buffer, in compliance with Section V.A.8. of the Subdivision Regulations;**
- 5) **placement of a note on the Final Plat stating the site must comply with the City of Mobile storm water and flood control ordinances: *(Must comply with the Mobile County Flood Damage Prevention Ordinance. Development shall be designed to comply with the storm water detention and drainage facility requirements of the City of Mobile storm water and flood control ordinances, and requiring submission of certification from a licensed engineer certifying that the design complies with the storm water detention and drainage facility requirements of the City of Mobile storm water and flood control ordinances prior to the issuance of any permits.);***
- 6) **compliance with Fire Department comments *(All projects within the City of Mobile Fire Jurisdiction must comply with the requirements of the 2009***

Pine Acres Subdivision, Resubdivision of Lot 1  
December 22, 2014

*International Fire Code, as adopted by the City of Mobile. As per Appendix D, Section D107.1, one and two family developments with more than 30 dwelling units shall be provided with separate and approved fire apparatus access roads and shall meet the requirements of Section D104.3.);*

- 7) placement of a note on the Final Plat stating that approval of all applicable Federal, state and local agencies is required for wetland issues, if any, prior to the issuance of any permits or land disturbance activities;
- 8) placement of a note on the Final Plat stating that each lot is limited to one curb cut, with the size, design, and location of the curb cuts to be approved by Mobile County Engineering and conform to AASHTO standards; and
- 9) placement of a note on the Final Plat stating that approval of all applicable federal, state, and local agencies is required for endangered, threatened, or otherwise protected species, if any, prior to the issuance of any permits or land disturbance activities.

After you have obtained all the necessary approval signatures and the plat has been recorded in the Mobile County Probate Office, seven copies of the recorded plat (including map book and page number) must be submitted to the Land Use Administration office. This procedure must be completed within one (1) year, or the Tentative Approval will expire.

It is also requested that a digital copy of the final plat be submitted to the Land Use Administration office once the plat has been submitted to Probate for recording. This may be submitted on disk or via e-mail at [marine.karapetyan@cityofmobile.org](mailto:marine.karapetyan@cityofmobile.org).

If you have any questions regarding this action, please call this office at 251-208-5895.

Sincerely,

**MOBILE CITY PLANNING COMMISSION**

Ms. Jennifer Denson, Secretary

By: 

Richard Olsen  
Deputy Director of Planning

cc: Erdman Surveying, LLC