



THE CITY OF MOBILE, ALABAMA
MOBILE CITY PLANNING COMMISSION

LETTER OF DECISION

May 29, 2018

Ronald K. and Betty G. Mair
2817 Dauphin Street
Mobile, AL 36606

Re: 2817 Dauphin Street
(Southeast corner of Dauphin Street and Hogans Lane).
Council District 1
SUB-000496-2018
Ronald Mair Subdivision

Dear Applicant(s)/ Property Owner(s):

At its meeting on May 17, 2018, the Planning Commission considered the above referenced subdivision application.

After discussion, the Planning Commission tentatively approved the above referenced subdivision, subject to the following conditions:

- 1) retention of the right-of-way widths of Dauphin Street and Hogans Lane on the Final Plat;
- 2) retention of the 25' minimum building setback line along all street frontages;
- 3) retention of the lot size label on the Final Plat, or the furnishing of a table on the Final Plat providing the same information;
- 4) placement of a note on the Final Plat stating that the lot is limited to two curb cuts to Dauphin Street and one curb-cut to Hogans Lane, with size, location and design to be approved by Traffic Engineering and conform to AASHTO standards;
- 5) placement of a note on the Final Plat stating that no structure may be placed or constructed within the 7.5' drainage and utility easement;
- 6) compliance with the Engineering comments: *[FINAL PLAT COMMENTS (should be addressed prior to submitting the FINAL PLAT for review and/or signature by the City Engineer): A. Provide all of the required information on the SUBDIVISION PLAT (i.e. signature blocks, signatures, certification statements, written legal description, required notes, legend, scale, bearings and distances) that is required by*

the current Alabama State Board of Licensure for Professional Engineers and Land Surveyors. B. Add a signature block for the Owner, Notary Public, Planning Commission, Traffic Engineer, and City Engineer. C. Provide the Surveyor's, Owner's (notarized), Planning Commission, and Traffic Engineering signatures. D. Add a note to the SUBDIVISION PLAT stating that as shown on the 1984 aerial photo (FLIGHT 25 - #73) LOT 1 will receive historical credit of impervious area towards stormwater detention requirement per Mobile City Code, Chapter 17, Storm Water Management and Flood Control. (Coordinate with City Engineering Department staff to establish the exact amount prior to the submittal of a Final Plat for review. E. Add a note to the SUBDIVISION PLAT stating that a Land Disturbance permit will be required for any land disturbing activity in accordance with Mobile City Code, Chapter 17, Storm Water Management and Flood Control; the City of Mobile, Alabama Flood Plain Management Plan (1984); and, the Rules For Erosion and Sedimentation Control and Storm Water Runoff Control. F. Add a note to the Plat stating that the approval of all applicable federal, state, and local agencies (including all storm water runoff, wetland and floodplain requirements) will be required prior to the issuance of a Land Disturbance permit. G. Add a note that sidewalk is required to be constructed, and/or repaired, along the frontage of each lot, or parcel, at time of new development or construction, unless a sidewalk waiver is approved. H. Add a note to the plat stating that all easements shall remain in effect until vacated through the proper Vacation process. I. Provide a copy of the FINAL SUBDIVISION PLAT to the Engineering Dept. for review. No signatures are required on this drawing. J. After addressing all of the FINAL SUBDIVISION PLAT review comments by the Engineering Dept. provide the red-line markup, the ORIGINAL (with all other signatures) and one (1) copy of the revised original (signatures not required) of the revised Final Plat to the Engineering Department.];

- 7) compliance with the Traffic Engineering comments (Lot is limited to two curb cuts to Dauphin Street and one curb-cut to Hogans Lane, with size, location and design to be approved by Traffic Engineering and conform to AASHTO standards.);*
- 8) compliance with the Urban Forestry comments: [Property to be developed in compliance with state and local laws that pertain to tree preservation and protection on both city and private properties (State Act 2015-116 and City Code Chapters 57 and 64).]; and*
- 9) compliance with the Fire Department comments: [All projects within the City Limits of Mobile shall comply with the requirements of the City of Mobile Fire Code Ordinance (2012 International Fire Code).].*

After you have obtained all the necessary approval signatures and the plat has been recorded in the Mobile County Probate Office, seven copies of the recorded plat (including map book and page number) must be submitted to the Planning and Zoning Department office. This procedure must be completed within one (1) year, or the Tentative Approval will expire.

Please also submit a CAD compatible (DXF) digital copy of the final plat to the Planning and Zoning Department office once the plat has been submitted to Probate for recording. This may be submitted on disk, flash drive, memory stick, or via e-mail to planning@cityofmobile.org.

Ronald Mair Subdivision
May 29, 2018

If you have any questions regarding this action, please call this office at 251-208-5895.

Sincerely,

MOBILE CITY PLANNING COMMISSION

Ms. Jennifer Denson, Secretary

By: 
Margaret Pappas
Deputy Director of Planning & Zoning

cc: Polysurveying & Engineering, Inc.