

MAWSS/MUNICIPAL PARK SUBDIVISION

Engineering Comments: FINAL PLAT COMMENTS (should be addressed prior to submitting the FINAL PLAT for review and/or signature by the City Engineer):

- A. Provide all of the required information on the SUBDIVISION PLAT (i.e. signature blocks, signatures, certification statements, written legal description, required notes, legend, scale, bearings and distances) that is required by the current Alabama State Board of Licensure for Professional Engineers and Land Surveyors.
- B. Add legible street names to the vicinity map.
- C. National Wetlands Inventory (NWI) mapping, as shown on City of Mobile GIS information, indicates that there is potential for wetlands within the property or properties shown on this plat. Show and label the delineated wetlands, or provide a note stating that the wetlands shown on this plat are scaled from the NWI data and have not been delineated.
- D. Provide a note that a 25' riparian buffer may be required, during development, along the edge of anything considered by ADEM to be a water of the state.
- E. Show and label the MFFE (Minimum Finished Floor Elevation) on each lot that contains an AE, V, or X (shaded) flood zone designation. BFE = 82.0.
- F. Show and label each and every Right-Of-Way and easement including that portion of Museum Drive.
- G. Provide the Surveyor's and Owner's (notarized) signatures.
- H. Add a note to the SUBDIVISION PLAT stating that as shown on the 1984 aerial photo (FLIGHT 22 - #78) LOTS 1 and 2 will receive historical credit of existing (1984) impervious area towards stormwater detention requirement per Mobile City Code, Chapter 17, Storm Water Management and Flood Control) as follows: LOT 1 – 3,900 sf and LOT 2 – NONE. The existing Museum Drive (and cul-de-sac) pavement are not included in the amount allowed for LOT 1.
- I. Add a note that a Land Disturbance permit will be required for any land disturbing activity in accordance with Mobile City Code, Chapter 17, Storm Water Management and Flood Control; the City of Mobile, Alabama Flood Plain Management Plan (1984); and, the Rules For Erosion and Sedimentation Control and Storm Water Runoff Control.
- J. Add a note that the approval of all applicable federal, state, and local agencies (including all storm water runoff, wetland and floodplain requirements) will be required prior to the issuance of a Land Disturbance permit.
- K. Add a note that sidewalk is required to be constructed, and/or repaired, along the frontage of each lot, or parcel, at time of new development or construction, unless a sidewalk waiver is approved.
- L. Add a note that all existing and proposed detention facilities, common areas, and wetlands shall be the responsibility of the Property Owner(s), and not the responsibility of the City of Mobile.
- M. Add a note that all easements shall remain in effect until vacated through the proper Vacation process.
- N. Email a pdf copy of the FINAL SUBDIVISION PLAT and LETTER OF DECISION to the Permitting Engineering Dept. for review at land.disturbance@cityofmobile.org prior to obtaining any signatures. No signatures are required on the drawing.
- O. After addressing all of the FINAL SUBDIVISION PLAT review comments provide the ORIGINAL (with all signatures except for the Planning Commission, Traffic Engineering, and

City Engineer), one (1) copy, and a transmittal letter to the Engineering Permitting Department. They can be dropped off at 205 Government St. or mailed to PO Box 1827, Mobile, AL, 36633.

Traffic Engineering Comments: Driveway number, size, location, and design to be approved by Traffic Engineering and conform to AASHTO standards.

Urban Forestry Comments: Property to be developed in compliance with state and local laws that pertain to tree preservation and protection on both city and private properties [Act 929 of the 1961 Regular Session of the Alabama Legislature (Acts 1961, p. 1487), as amended, and City Code Chapters 57 and 65]. Private removal of trees in the right-of-way will require approval of the Mobile Tree Commission. Removal of heritage trees from undeveloped residential sites, developed residential sites in historic districts, and all commercial sites will require a tree removal permit.

Fire Department Comments: All projects within the City Limits of Mobile shall comply with the requirements of the City of Mobile Fire Code Ordinance (2012 International Fire Code). Fire apparatus access is required to be within 150' of all commercial and residential buildings. A fire hydrant is required to be within 400' of non-sprinkled commercial buildings and 600' of sprinkled commercial buildings.

The plat illustrates the proposed 2-lot, 16.1± acre subdivision which is located on the North and South sides of Museum Drive at the South terminus of PFC John D. New Street, in Council District 7. The purpose of this application is to create two (2) legal lots of record from a single metes-and-bounds parcel. The applicant states the site is served by public water and sewer.

The site has been given a Parks and Open Space (POS) land use designation, per the Future Land Use Plan and Map, adopted on May 18, 2017 by the Planning Commission. The Future Land Use Plan and Map complements and provides additional detail to the Development Framework Maps in the Map for Mobile, adopted by the Planning Commission at its November 5, 2015 meeting.

This designation applies to parkland maintained in a natural, semi-natural state, or developed with facilities and set aside for human enjoyment and recreation or for the protection of wildlife or natural habitats. Parks may include squares, playgrounds, playfields, gardens, greens, greenways and blueways, and other recreational areas and facilities that are accessible to the public. Open space may include any open piece of land, publicly or privately held, that is undeveloped (has no buildings or other built structures). This designation is not intended to identify public land acquisition or to prohibit the development potential of individual properties.

The designation applies to all existing and future parks and open space within the City, including both active and passive uses. Open space, including public access to water bodies, is generally consistent with all other land use categories, i.e., a park can be located within any other land use category, either incidental to a development or as part of a publicly-owned or publicly-sponsored local, community or regional park. Therefore, a Parks and Open Space designation is deemed consistent with all land use categories in the Future Land Use Map.

It should be noted that the Future Land Use Plan and Map components of the Map for Mobile Plan are meant to serve as a general guide, not a detailed lot and district plan. In many cases the

designation on the new Future Land Use Map may match the existing use of land, but in others the designated land use may differ from what is on the ground today. As such, the Future Land Use Plan and Map allows the Planning Commission and City Council to consider individual cases based on additional information such as the classification request, the surrounding development, the timing of the request, and the appropriateness and compatibility of the proposed use and, where applicable, the zoning classification.

Subdivision review examines the site with regard to promoting orderly development, protecting general health, safety and welfare, and ensuring that development is correlated with adjacent developments and public utilities and services, and to ensure that the subdivision meets the minimum standards set forth in the Subdivision Regulations for lot size, road frontage, lot configuration, etc.

The primary purpose of the subdivision application at hand is to allow MAWSS and the City of Mobile to disentangle their interests in the site. The City has two large lease parcels on the proposed Lot 1, and the City will be taking ownership of the lot upon completion of the Subdivision process, while MAWSS will retain Lot 2. It should be noted that the subject site was included in multiple Planning Approvals through the years as part of the Langan Park Master Plan. As no changes are proposed to the site currently, no new Planning Approval will be required at this time.

The lots front onto the portion of Museum Drive that is a public, minor street, without curb and gutter, and has an existing compliant right-of-way of 80-feet, making no dedications necessary. Museum Drive continues through the proposed Lot 1, but is a private street at that point.

The 25' minimum building setback is shown along the public street portion of Museum Drive, and should be retained on the Final Plat, if approved.

In regards to access management, a note should be placed on the Final Plat stating Traffic Engineering comments, if approved.

The proposed lot sizes are provided in square feet and acres on the preliminary plat. If approved, this information should be retained on the Final Plat.

No easements are indicated on the preliminary plat. If any easements are recorded on the site they should be indicated and labeled on the Final Plat, and a note should be placed on the Final Plat stating that no structure may be placed or constructed within any easement without permission of the easement holder.

Based on the preceding, this application is recommended for Tentative Approval subject to the following conditions:


- 1) Retention of the 25-foot minimum building setback line along the public portion of Museum Drive;
- 2) Retention of the current right-of-way for Museum Drive;
- 3) Retention of the lot size in both square feet and acres, or the furnishing of a table on the Final Plat providing the same information;
- 4) Placement of a note on the Final Plat stating that no structure may be constructed or placed within any easement without the permission of the easement holder, if applicable;

- 5) Compliance with the Engineering comments: (FINAL PLAT COMMENTS (should be addressed prior to submitting the FINAL PLAT for review and/or signature by the City Engineer): A. Provide all of the required information on the SUBDIVISION PLAT (i.e. signature blocks, signatures, certification statements, written legal description, required notes, legend, scale, bearings and distances) that is required by the current Alabama State Board of Licensure for Professional Engineers and Land Surveyors. B. Add legible street names to the vicinity map. C. National Wetlands Inventory (NWI) mapping, as shown on City of Mobile GIS information, indicates that there is potential for wetlands within the property or properties shown on this plat. Show and label the delineated wetlands, or provide a note stating that the wetlands shown on this plat are scaled from the NWI data and have not been delineated. D. Provide a note that a 25' riparian buffer may be required, during development, along the edge of anything considered by ADEM to be a water of the state. E. Show and label the MFFE (Minimum Finished Floor Elevation) on each lot that contains an AE, V, or X (shaded) flood zone designation. BFE = 82.0. F. Show and label each and every Right-Of-Way and easement including that portion of Museum Drive. G. Provide the Surveyor's and Owner's (notarized) signatures. H. Add a note to the SUBDIVISION PLAT stating that as shown on the 1984 aerial photo (FLIGHT 22 - #78) LOTS 1 and 2 will receive historical credit of existing (1984) impervious area towards stormwater detention requirement per Mobile City Code, Chapter 17, Storm Water Management and Flood Control) as follows: LOT 1 – 3,900 sf and LOT 2 –NONE. The existing Museum Drive (and cul-de-sac) pavement are not included in the amount allowed for LOT 1. I. Add a note that a Land Disturbance permit will be required for any land disturbing activity in accordance with Mobile City Code, Chapter 17, Storm Water Management and Flood Control); the City of Mobile, Alabama Flood Plain Management Plan (1984); and, the Rules For Erosion and Sedimentation Control and Storm Water Runoff Control. J. Add a note that the approval of all applicable federal, state, and local agencies (including all storm water runoff, wetland and floodplain requirements) will be required prior to the issuance of a Land Disturbance permit. K. Add a note that sidewalk is required to be constructed, and/or repaired, along the frontage of each lot, or parcel, at time of new development or construction, unless a sidewalk waiver is approved. L. Add a note that all existing and proposed detention facilities, common areas, and wetlands shall be the responsibility of the Property Owner(s), and not the responsibility of the City of Mobile. M. Add a note that all easements shall remain in effect until vacated through the proper Vacation process. N. Email a pdf copy of the FINAL SUBDIVISION PLAT and LETTER OF DECISION to the Permitting Engineering Dept. for review at land.disturbance@cityofmobile.org prior to obtaining any signatures. No signatures are required on the drawing. O. After addressing all of the FINAL SUBDIVISION PLAT review comments provide the ORIGINAL (with all signatures except for the Planning Commission, Traffic Engineering, and City Engineer), one (1) copy, and a transmittal letter to the Engineering Permitting Department. They can be dropped off at 205 Government St. or mailed to PO Box 1827, Mobile, AL, 36633.);
- 6) Placement of a note on the Final Plat stating the Traffic Engineering comments: (Driveway number, size, location, and design to be approved by Traffic Engineering and conform to AASHTO standards.);
- 7) Compliance with the Urban Forestry comments: (Property to be developed in compliance with state and local laws that pertain to tree preservation and protection on both city and private properties [Act 929 of the 1961 Regular Session of the Alabama Legislature (Acts

1961, p. 1487), as amended, and City Code Chapters 57 and 65]. Private removal of trees in the right-of-way will require approval of the Mobile Tree Commission. Removal of heritage trees from undeveloped residential sites, developed residential sites in historic districts, and all commercial sites will require a tree removal permit.); and

- 8) Compliance with the Fire Department comments: *All projects within the City Limits of Mobile shall comply with the requirements of the City of Mobile Fire Code Ordinance (2012 International Fire Code). Fire apparatus access is required to be within 150' of all commercial and residential buildings. A fire hydrant is required to be within 400' of non-sprinkled commercial buildings and 600' of sprinkled commercial buildings.).*

LOCATOR MAP




APPLICATION NUMBER 3 DATE August 5, 2021

APPLICANT MAWSS/Municipal Park Subdivision

REQUEST Subdivision



LOCATOR ZONING MAP




APPLICATION NUMBER 3 DATE August 5, 2021

APPLICANT MAWSS/Municipal Park Subdivision

REQUEST Subdivision



FLUM LOCATOR MAP



APPLICATION NUMBER 3 DATE August 5, 2021


APPLICANT MAWSS/Municipal Park Subdivision

REQUEST Subdivision

- | | | | |
|---------------------------|-----------------------------------|---------------------|--------------------|
| Low Density Residential | Neighborhood Center - Traditional | Downtown Waterfront | Parks & Open Space |
| Mixed Density Residential | Neighborhood Center - Suburban | Light Industry | Water Dependent |
| Downtown | Traditional Corridor | Heavy Industry | |
| District Center | Mixed Commercial Corridor | Institutional | |



ENVIRONMENTAL LOCATOR MAP




APPLICATION NUMBER 3 DATE August 5, 2021

APPLICANT MAWSS/Municipal Park Subdivision

REQUEST Subdivision



MAWSS/MUNICIPAL PARK SUBDIVISION



APPLICATION NUMBER 3 DATE August 5, 2021

R-A	R-3	T-B	B-2	B-5	MUN	SD-WH	T5.1
R-1	R-B	B-1	B-3	I-1	OPEN	T3	T5.2
R-2	H-B	LB-2	B-4	I-2	SD	T4	T6




MAWSS/MUNICIPAL PARK SUBDIVISION



APPLICATION NUMBER 3 DATE August 5, 2021



DETAIL SITE PLAN



APPLICATION NUMBER 3 DATE August 5, 2021

APPLICANT MAWSS/Municipal Park Subdivision

REQUEST Subdivision

